



MODEL NUMBER	NOMINAL SIZE IN. W X H X D	ACTUAL SIZE IN. W X H X D	RATED AIR FLOW CFM	INITIAL RESISTANCE IN. W.G.	MEDIA AREA SQ. FT.
HE40-STD4	12 X 24 X 4	11-3/8 X 23-3/8 X 3-3/4	1000	.20	11.2
HE40-STD4	16 X 20 X 4	15-1/2 X 19-1/2 X 3-3/4	1110	.20	12.5
HE40-STD4	16 X 25 X 4	15-1/2 X 24-1/2 X 3-3/4	1400	.20	15.6
HE40-STD4	18 X 24 X 4	17-3/8 X 23-3/8 X 3-3/4	1500	.20	16.2
HE40-STD4	20 X 20 X 4	19-1/2 X 19-1/2 X 3-3/4	1400	.20	15.6
HE40-STD4	20 X 24 X 4	19-3/8 X 23-3/8 X 3-3/4	1670	.20	18.7
HE40-STD4	20 X 25 X 4	19-1/2 X 24-1/2 X 3-3/4	1730	.20	19.6
HE40-STD4	24 X 24 X 4	23-3/8 X 23-3/8 X 3-3/4	2000	.20	22.4

#### STANDARD CONSTRUCTION

- 100% Synthetic White Un-Dyed Media
- 9 Pleats Per Foot
- Expanded Metal Pleat Supports
- Moisture Resistant Beverage Board Frame
- Double Wall Frame
- (2) Rows of Fingers on Air Entering Side

#### NOTES

- MERV 8 Per ASHRAE 52.2-2012  
MERV 8-A Per ASHRAE 52.2-2012 Appendix J.  
Tested at 492 FPM on 24x24x4
- Final Resistance: 1.0" W.G.
- Rated Velocity: 500 FPM
- Class 2 Filter Per UL Standard 900 for Flammability
- Maximum Operating Temperature: 225 Deg. F

 Air Cleaning Specialists  
11088 Gravois Industrial Ct.  
St. Louis, MO 63128  
(866) 455-2128  
purolatorfilters.com

CONTACT FACTORY TO  
VERIFY REVISION LEVEL

TOLERANCES  
UNLESS OTHERWISE SPECIFIED

FRACTIONAL —  
DECIMAL —  
ANGLES —

ALL DIMENSIONS IN INCHES

DRAWING NAME

HI-E 40 PLEAT (4" DEPTH)

APPROVED BY

*K. O.*

SPECIFICATION NO.

MKT-P-00554

PAGE

1 OF 1

SCALE

NONE

DWG. SIZE

A

REVISION

D

REVISION DATE

11-19-13

CONFIDENTIAL - DO NOT COPY. THIS MATERIAL IS TRADE SECRET AND PROPRIETARY BEING EXCLUSIVELY OWNED BY CLC AIR. THE EXPRESSION OF THE INFORMATION CONTAINED HEREIN IS PROTECTED UNDER FEDERAL COPYRIGHT LAWS AND ALL COPYING IS PROHIBITED AND MAY BE SUBJECT TO CRIMINAL PENALTIES.