


MODEL NUMBER	NOMINAL SIZE W X H X D	ACTUAL SIZE W X H X D	RATED AIR FLOW CFM	INITIAL RESISTANCE IN W.C.	MEDIA AREA SQ. FT.
HE40-STD6	12 X 24 X 6	11-3/8 X 23-3/8 X 5-7/8	1000	.29	16.9
HE40-STD6	16 X 20 X 6	15-1/2 X 19-1/2 X 5-7/8	1110	.29	18.9
HE40-STD6	16 X 25 X 6	15-1/2 X 24-1/2 X 5-7/8	1400	.29	23.6
HE40-STD6	18 X 24 X 6	17-3/8 X 23-3/8 X 5-7/8	1500	.29	26.3
HE40-STD6	20 X 20 X 6	19-1/2 X 19-1/2 X 5-7/8	1400	.29	23.7
HE40-STD6	20 X 24 X 6	19-3/8 X 23-3/8 X 5-7/8	1670	.29	28.2
HE40-STD6	20 X 25 X 6	19-1/2 X 24-1/2 X 5-7/8	1730	.29	29.5
HE40-STD6	24 X 24 X 6	23-3/8 X 23-3/8 X 5-7/8	2000	.29	33.8




STANDARD CONSTRUCTION

1. 100% Synthetic White Un-Dyed Media
2. 9 Pleats Per Foot
3. Expanded Metal Pleat Supports
4. Moisture Resistant Beverage Board Frame
5. Double Wall Frame
6. (2) Rows of Fingers on Air Entering Side

NOTES

1. MERV 8 per ASHRAE 52.2-2012
MERV 8-A per ASHRAE 52.2-2012 Appendix J
Tested at 492 FPM on 24x24x6 filter size
2. Final Resistance: 1.0" W.G.
3. Rated Velocity: 500 FPM
4. Classified per UL Standard 900 for Flammability
5. Maximum Operating Temperature: 225 deg. F

 <p>Air Cleaning Specialists 11088 Gravois Industrial Ct. St. Louis, MO 63128 (866) 455-2128 purolatorfilters.com</p>	TOLERANCES UNLESS OTHERWISE SPECIFIED		DRAWING NAME Hi-E 40 PLEAT 6" DEPTH		
	FRACTIONAL — DECIMAL — ANGLES —	APPROVED BY <i>K. Quinn</i> SPECIFICATION NO. MKT-P-00541 SCALE NONE DWG. SIZE A REVISION NEW REVISION DATE 11-26-13		PAGE 1 OF 1	
CONTACT FACTORY TO VERIFY REVISION LEVEL	ALL DIMENSIONS IN INCHES		<small>CONFIDENTIAL - DO NOT COPY. THIS MATERIAL IS TRADE SECRET AND PROPRIETARY BEING EXCLUSIVELY OWNED BY GLCAIR. THE EXPRESSION OF THE INFORMATION CONTAINED HEREIN IS PROTECTED UNDER FEDERAL COPYRIGHT LAWS AND ALL COPYING IS PROHIBITED AND MAY BE SUBJECT TO CRIMINAL PENALTIES.</small>		